

**JOINT ELECTRICITY REGULATORY COMMISSION FOR
THE STATE OF GOA AND UNION TERRITORIES
GURGAON**

Coram
Dr. V. K. Garg, Chairperson
Shri R. K. Sharma, FIE Member
Petition No.....37/ 2011

In the matter of

Intimation regarding release of power more than 25000 KVA on 66 KV system to M/S Alok Industries Sayali till the installation work of 220 KV switching station is completed.

And in the matter of

Electricity Department, UT Administration, Dadra and Nagar HaveliPetitioner

Present

For the petitioner:

1. Shri. R.B. Chaubal Deputy Engineer

ORDER

Date: 14.07.2011

As provided in clause 2.2 of JERC (Electricity Supply Code) Regulations 2010, the petitioner has agreed to supply power more than 25000 KVA on 66 KV system to M/S Alok Industries, Sayali in place of required voltage level of 220 KV which shall be adopted subsequently when the 220 KV system is ready and filed this petition with the Commission for their intimation as is required under above mentioned regulation of the Commission.

In order to examine whether clause 2.2 of JERC (Electricity Supply Code) Regulations 2010 is applicable or not, the Commission observes as under:

1. For better appreciation of the proposal, the petitioner is directed to file a circuit/line diagram of the section under reference, existing and proposed, plotted on a map of the area of appropriate scale, in order that it is legible.
2. That the release of proposed load on 66 KV is technically feasible based on what is mentioned in para 15 of their petition is not enough and does not satisfy the Commission. A detailed analysis needs to be carried out keeping in view the voltage

profile, incremental losses, existing switchgear capacity, loading capacity of 66 KV line and other technical parameters required to be examined in this respect.

3. A copy of the latest policy guide lines and memorandum issued dated 26.04.11 as mentioned in para 4 of the petition be submitted with the Commission.
4. It is a case of additional power to the consumer. The petitioner to confirm that they have followed the provisions of clause 6.4 of the JERC (Electricity Supply Code) Regulations 2010.
5. Contents of para 7,8,10 of the petition and those of para 11 are contradictory and needs to be explained further.
6. As per para 3 of the petition, A contracted demand of 29025KVA and 31800 KVA is being served on 66 KV level, which is in violation of the clause 4 of the Tariff Schedule annexed as Appendix 1, with the Tariff order for FY 2010-11. This needs to be explained.

The reply on above issues shall be filed by 7th September 2011 and the matter shall be heard on 14.09.11.

(R.K. SHARMA)
Member

(Dr. V.K. GARG)
Chairperson